

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

CERTIFICATE

No. B 098200 0028 Rev. 00

Holder of Certificate: **Caledonian Cables Limited**
1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Certification Mark:



Product: **PVC insulated PVC sheathed cables**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 64100180446001

Valid until: 2023-08-09

Date, 2018-08-10

(Boris Ouyang)



Product Service

CERTIFICATE

No. B 098200 0028 Rev. 00

Model(s): FGD300 05VV-U, FGD300 05VV-R,
 FGD200 05VV-U, FGD200 05VV-R,
 FGD300-E 05VV-U, FGD300-E 05VV-R,
 FGD200-E 05VV-U, FGD200-E 05VV-R,
 6181Y, 6192Y, 6193Y, 6241Y, 6242Y, 6243Y

Parameters: Rated voltage: 300/500V
 Conductors: Plain annealed copper wires
 Insulation: PVC, TI1
 Sheath: PVC, Type 6
 Size: See below table

BS code	Factory Code	Range
6181Y	FGD300 05VV-U	1x1.0 to 1x2.5
	FGD300 05VV-R	1x4.0 to 1x35
6192Y	FGD200 05VV-U	2x1.0 to 2x2.5
	FGD200 05VV-R	2x1.5 to 2x16
6193Y	FGD200 05VV-U	3x1.0 to 3x2.5
	FGD200 05VV-R	3x4 to 3x16
6241Y	FGD300-E 05VV-U	1x1.0 to 1x1.5
	FGD300-E 05VV-R	1x1.5
6242Y	FGD200-E 05VV-U	2x1.0 to 2x2.5
	FGD200-E 05VV-R	2x1.5 to 2x16
6243Y	FGD200-E 05VV-U	3x1.0 to 3x2.5
	FGD200-E 05VV-R	3x4 to 3x16

Tested according to: BS 6004:2012

Production Facility(ies): 096882

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認 證 證 書 ◆ CERTIFICADO ◆ CERTIFICAT