



Product Service

CERTIFICATE

No. B 17 06 98200 002

Holder of Certificate: Caledonian Cables Limited1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG**Production Facility(ies):** 96882**Certification Mark:****Product:** **Flame retardant cables
Single core non-sheathed LSZH cables****Model(s):** **FTX100 07Z-U (H07Z-U), FTX100 07Z-R (H07Z-R),
FTX100 07Z-K (H07Z-K)****Parameters:**
Voltage: 450/750V
Conductors: Plain or tinned copper wires to IEC 60228
class 1(-U), class 2(-R), class 5(-K)
Insulation: Thermosetting cross-linked Polyolefin,
type EI5
Sizes:
FTX100 07Z-U (H07Z-U): 1C x 1.5mm² to 1C x 10mm²;
FTX100 07Z-R (H07Z-R): 1C x 1.5mm² to 1C x 630mm²;
FTX100 07Z-K (H07Z-K): 1C x 1.5mm² to 1C x 240mm²**Tested according to:** EN 50525-3-41:2011

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704101685905-00**Valid until:** 2022-06-26**Date,** 2017-06-27
(Yi Zhu)

Page 1 of 1

