



Product Service

CERTIFICATE

No. B 18 01 98200 015

Holder of Certificate: **Caledonian Cables Limited**

1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Production Facility(ies):

96882

Certification Mark:



Product:

**Plastic insulated cables
Cable for use in photovoltaic systems**

Model(s):

H1Z2Z2-K 1×1,5...240 mm²

Parameters:


Rated Voltage:	DC 1500V (between conductors and between conductor and earth) AC U ₀ /U: 1,0/1,0 kV
Application Class:	A
Protection Class:	II
Ambient Temperature:	-40°C~ + 90°C
Max. Temperature at conductor:	120°C

Tested according to: EN 50618:2014

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704071715202-00

Valid until: 2023-01-04


Date, 2018-01-22

(Yaqun Liu)

Page 1 of 1

